



Joint form			
	DESCRIPTION	STANDARD	MATERIAL
A	8"Flange	DIN 2501 PN10 / ANSI 150#	Reinforced Polyamide
B	8"Flange	DIN 2501 PN10 / ANSI 150#	Reinforced Polyamide
C	3"Flange	DIN 2501 PN10 / ANSI 150#	Reinforced Polyamide

11							
10		Controller	1				
9		Two-position three-way valve	7	Reinforced Polyamide			
8		DP switch	1	SS304			
7		Outlet pipe	1	HDPE 8"			
6		Drain pipe	1	HDPE 3"			
5		Coupling	28	Reinforced Polyamide			
4		Inlet pipe	1	HDPE 8"			
3		Water source filter	1	Reinforced Polyamide			
2		Pressure gauge	2	SS304			
1		Discfilter unit	7	Reinforced Polyamide	9.4kg		
ITEM	PART NO.	DESCRIPTION	Q' TY	MATERIAL	EATH WT.	TOL. WT.	REMARKS

Explanation:

1. Need manual valve on inlet and outlet°
2. Ensure fluent drain.
3. Power supply: 220VAC 50Hz
4. Gross weight: 165KG                      Operation weight: 360KG
5. The installation base of the equipment is a 20cm height of cement platform which need expansion bolt to fix the equipment on after installation.
6. There are three types of piping. Short name of PE piping is P, and S instead of stainless stell piping, C is carbon steel piping.

## JYP3-7-8 DISCFILTER



BEIJING KANGJIE ZHICHEN  
WATER TREATMENT CO., LTD.

RESPONS: Eric  
REVISION: 03  
UNITS: mm  
DATE: 12/11/2015